

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

**FC-R-2017-39**  
**CUMBERLAND FIRE DISTRICT**  
**Resolution**

**RESOLUTION:** Authorizing the Finance Director to pay Woonsocket Door Sales Co., Inc. an amount not to exceed \$4,370.00

**WHEREAS:** Woonsocket Door Sales, Inc. replaced the garage door at Station 4, which was an emergency, as the replaced door was damaged and opened, and the fire apparatus was exposed to the elements.

**NOW, THEREFORE, BE IT RESOLVED BY THE CUMBERLAND FIRE DISTRICT AS FOLLOWS:**

**RESOLVED:** The Finance Director is authorized to pay Woonsocket Door, Inc. an amount not to exceed \$4,370.00.

Voted on this 18<sup>th</sup> day of December, 2017

28  
29

  
\_\_\_\_\_  
Cynthia Ouellette, Chairperson

**PASSED:**

**YAY: 5      NAY: 0**



Kenneth A. Finlay  
Chief of Department  
kfinlay@cumberlandfire.org

# CUMBERLAND FIRE DISTRICT

Headquarters Station Four  
3502 Mendon Road • Cumberland, RI 02864  
Phone: 401-658-0544 Fax: 401-658-2198  
www.cumberlandfire.org

Board of Fire Commissioners  
3502 Mendon Road  
Cumberland, RI 02864

November 10, 2017

Honorable Board:

Engine 4 was backing into Station 4, in the bay they usually occupy, when the overhead door began to operate due to a mechanical failure in the remote opener. The safety devices on this door only stop the door, and not reverse to open. This particular door when purchased 20 years ago, was a three-inch thick door. This door is no longer manufactured, so just replacing 1 panel was not an option. The new door purchased has an R-30 rating, and the safety switch has been upgraded to reverse the door operation so this event will not re-occur. Woonsocket Door responded immediately to secure the station, and performed the new installation on November 3, 2017.

Sincerely,

Chief Kenneth A. Finlay  
Cumberland Fire Department

